



Australian Government

Australian Nuclear Science & Technology Organisation

OPAL : Cold Neutron Source Commissioning, Operation and Heat Load




Outline

- 1. The OPAL Reactor and its Utilisation**
- 2. CNS Systems.**
- 3. Installation and Commissioning 2005-07.**
- 4. Operational Issues.**
- 5. Heat Load Measurement.**



OPAL Reactor

- 20 MW thermal open pool reactor
- Light water cooled and moderated
- Plate type compact LEU fuel
- Heavy water reflected
- Utilisation:
 - Radiopharmaceutical production
 - Beam research
 - Silicon doping




88


RRP4








OPAL Reactor



Reactor pool during initial water fill


Cold Beams Facilities



Cold neutron flux of 2.5×10^{10} n/cm²/s at the reactor face (energy spectrum peak at 2.4meV).

CNS Development Schedule

2001 – Project Initiation / Design




Ansto


Contractors




Cryo Refrigeration System



Cryo Refrigeration System




Vacuum & Moderator Systems



CNS In-pile



HNS Beam
tube



CNS Beam
tube


Vacuum
containment

Alignment
pin

Core

Reactor Recovery

Forced Evaporation – a transition from NO (cryogenic) mode to SO (warm) mode following system trip



Turbine Failure

- Turbine failure during transition from cryogenic conditions.
- Inferred cause - air contamination in He.
- Air ingress traced to D2 instrumentation.
- Instrumentation modified.



Turbine Failure Investigation

- 2 further failures at bearings ('06)
- Oil separation efficiency improved
- REGEN not performed in July '07 due to other engineering tests.
- Routine sampling discovered in 500 ppm of N₂.
- Such N₂ identification not typically possible (continuous cold operation).

What we knew


- Plant entirely pressurised
- Some leaks (outgoing) have been found
~ 150 L/day
- Helium dew point on the high side
- N2 contamination not high enough to cause turbine failure(?)



Investigation

- Air in-leak verified to be CONTINUOUS
- Air in-leak rate measured at ~ max. 0.5 L/day under different operating conditions, e.g. flow rates, compressor status, pressure setpoints...
- Oxygen/nitrogen ratio variable (analytical error).
- Large in-leaks previously responsible for turbine damage masked the current problem


Turbine Failure Investigation



Turbine Failure Investigation

CNS-RCS Operating Mode	In-Leakage (ppm /day)
Comp A, 30 Hz	3.5
Comp A, 30 Hz, 1.5 bar	5.6
Comp A, 50 Hz	8.3
Comp B, 50 Hz	12
Comp B, 50 Hz, 1.4 bar	12
NO mode	13
Comp A, with CO ₂ injection into shaft seal, ~ 10 ml/min	No change
Comp A, with He injection into shaft seal, ~ 10 ml/min	No change
Comp A, with He injection into shaft seal, ~ 100 ml/min	No change (TBC)


Turbine Failure Investigation

Background: 1×10^{-6} mbar.l.s

Position	Description	Leak Rate (mbar.l.s)
A, B, C, D	Seal Rings (general area, bagged)	8×10^{-9}
E, F	Shaft (general area, bagged)	8×10^{-9}
G	Inlet Valve (general area, bagged)	1.4×10^{-4}
H	Helium Outlet Flange	1×10^{-8}
I	Oil Inlet Flange	1×10^{-8}
J	HP Flange	2×10^{-7}
C	Seal Ring, inner (upper section)	$1 \times 10^{-3}, 5.5 \times 10^{-5}$
A	Seal Ring, outer (upper section)	3×10^{-5}
D	Seal Ring, inner (lower section)	1×10^{-5}
B	Seal Ring, outer (lower section)	1×10^{-6}
K	Compressor Head Flange	2×10^{-7}
L	Inlet Valve Flange	3×10^{-7}


Turbine Failure Investigation

- To pin-point leak mechanism
 - Vacuum test
 - Leak tests
 - Tracer gases
 - Blanketing gases




Turbine Failure Investigation

- NMR analysis of oil – doublet absent (implying oxidation)




Turbine Failure Investigation

- Compressor oil oxidation (acetaldehyde CH₃CHO) verified by FT-IR – cause of 2 turbine damages in 2006




Turbine Failure Investigation




CNS In-pile

Moderator and Displacer	AlMg5	3741 gram
Moderator	D2	19.62 litre
Nominal D2 Temperature		25 K
Nominal D2 Pressure		330 kPa a



Heat Load

Measured Heat Load on the CNS In-pile by Cryogenic Helium Thermal Balance
Linear fits indicate nuclear heat load (W/MW) by the slope and non-nuclear heat load by the offset (W)



Heat Load

Element	Heat Load		
	Total (D2 Liq. 20K)	Total (D2 Vap. 35K)	D2 only
Design conservative heat load (W)	(178.7) 293.1		
Non-nuclear Heat Load (W)	388	363	25 (6%)
Nuclear Heat Load (W/MW)	180.5	85.7	94.8 (53%)

0.023 W/MW/g - for AlMg5 heat load


0.030 W/MW/g - for D2 heat load

Heat Load


	Size	Design Heat load		Measured
		(2002)	(2008)	
		BOC	EOC	
Liquid D ₂	19.6 l	1397	1376	1921
D ₂ Cell	1533 g		998	
Displacer	600 g		391	
Jacket	1537 g		995	
Metal		2337	2300	2076
Thermal rad.		350	350	388
Total (less isotope source)		4084 W	4026 W	4385 W (7%)

Moderator Temperature


Normalised Heat Load (W/MW)




Pressure (kPa)



Thermosiphon Temperature




Reactor power - 15 MW. Loss of cooling




Thermosiphon Temperature

(He @ 24K, Reactor 1MW, 570 W heating)



Thermosiphon Temperature




Cold Beams

Heat Load	Contract Requirement	Operation
CG 3 Flux at reactor face	1.4 E10 n/cm ² /s	1.8 E10 n/cm ² /s
CG 4 Flux at reactor face	1.4 E10 n/cm ² /s	2.49 E10 n/cm ² /s
CG 3 Spectrum peak	< 4.2 meV	3.05 meV
CG 4 Spectrum peak	< 4.2 meV	2.35 meV


Spectrum

After Shutdown






Spectrum



Total counts and long wavelengths drop substantially above 21.5 K



INVAP
Ansto




CNS Characteristics

Parameter	Value
Reactor power	20 MW
Moderator type	Liquid Deuterium
Moderator volume	20 litres
Moderator Temperature	~ 23 K
Moderator circulation / cooling	By natural circulation in a sub-cooled Deuterium Thermosiphon, He cooled.
Nominal heat removal capacity	5000 W
Average Cold Neutron Flux in Cell	$7.3 \cdot 10^{13} \text{ cm}^{-2} \cdot \text{sec}^{-1}$
Cold Neutron Flux at Reactor Face	$1.4 \cdot 10^{10} \text{ cm}^{-2} \cdot \text{sec}^{-1}$
Moderator Cell material	AlMg5 Alloy
VC material	Zr-Nb Alloy
VC design pressure	1.6 MPa
Commissioning	Year 2005


CNS In-pile

Vacuum
containment


Liquid
 D_2
circuit



Helium
circuit



D_2O
circuit



CNS Description

1. In-pile Components (also combining a reflector plug)

Vacuum containment: Zircadyne (ZrNb2.5%)

Moderator chamber: Aluminium (AlMg5)

Sub-contracted: PNPI

2. Cryogenic Refrigeration System

He circuit, Brayton cycle, 19.8K at 5000W

Sub-contracted: Air Liquide

3. Moderator System

Liquid deuterium, ~ 24K, 20 m³, passive

4. Vacuum System

2 off (redundancy)

5. Gas Blanketing System

He / N₂

Heat Load


	Size	Design Heat load (2001)	Measured (2008)
Liquid D ₂	19.6 l	1357 W	1921 W
D ₂ Cell	1533 g	998 W	
Displacer	600 g	391 W	
Jacket	1537 g	995 W	
Metal		2384 W	2076 W
Total		3741 W	3997

CNS In-Pile Characteristics

Parameter	Nominal Value
Heat load on the Moderator Chamber	4300 W
D2 pressure	330 kPa
He T to the Chamber	19 K
He T to the HX	19 K
Total cooling He flow rate	160 g/s
He pressure after the TS	150 kPa
Vacuum around the Thermosiphon	$1.3 \cdot 10^{-2}$ Pa


Heat Load


LD2 Heat Load



Heat Load

D2 reservoir pressure consumed by LD2






- Yellow arrow: liquid deuterium flow
- Blue arrow: cold helium flow through the Heat Exchanger
- Cyan arrow: cold helium flow through the Moderator Chamber
- Red arrow: helium flow to the refrigerator

1 - shell and tube counter flow heat exchanger,
2 - tube-in-tube parallel flow heat exchanger as a downwards tube,
3 - moderator chamber,
4 - tube-in-tube parallel flow heat exchanger as an upwards tube.

Thermosiphon Temperature



In-pile Prototype Testing (PNPI)

AIM: To prove heat removal by thermosiphon

PROTOTYPE: Moderator chamber and thermosiphon. Two electric heaters modelled nuclear heating.



RESULTS:

Operation in normal cryogenic mode with 4300 W heat input.

Operation in warm stand-by mode with 2650 W heat input.

RCS Factory Acceptance Test (Air Liquid)



RCS Factory Acceptance Test (Air Liquide)

TEST PROGRAM – Jan 2004

CONCLUSIONS

- 5.6 kW heat removal capacity.
- Stand-by operation, and transition between modes successful.


LESSONS LEARNT

- The cryogenic helium bypass loop
- Helium relief tank
- Helium contamination



Cold Commissioning

Transition from SO (warm) mode to NO (cryogenic) mode with simulated power




Turbine Failure Investigation

- Compressor shaft seal modified




Thermosiphon Temperature


Heat Load	Prototype tests	Operation
D2	2170 W	1921 W
Vessel	2648W	2076 W





Thermosiphon Temperature



OPAL Reactor Facility



OPAL Reactor Facility



Operation

Normal Operating Mode (NO)

Stand-by Operating Mode (SO)

Halt Mode

Fast Warm-up – rapid deuterium vapour warm-up

Forced Evaporation – accelerated return to reactor power (reactor poison-out)

Helium injection into the vacuum containment